

107. Recommended spare parts: SE, SL 9-30 kW

50/60 Hz

Customer Information

Project title:	Customer name:
Reference number:	Customer number:
Customer contact:	Customer phone number: (____)
	Fax number: (____)

Pump information

Quotation made by

Type		Prod. No.	
P.c.	ø mm	No.	
▽	T °C	P	Insul. class:
Model	Pol	Hz	V
P ₁ /P ₂ kW	I _N	A _{start}	A _N /min
Cosφ		Weight	kg
Ex			

GRUNDFOS
CH-6105 Schachen

Company name: _____

Prepared by: (____) _____

Phone number: (____) _____

Fax number: (____) _____

Date: _____

Quote number: _____

Recommended spare parts

Kit - Spare - Bulk	Recommended service parts						Product number
	1 pump		2 to 3 pumps		4 to 7 pumps		
	2 years units per pump	5 years units per pump	2 years units per pump	5 years units per pump	2 years units per pump	5 years units per pump	
Kit, Shaft seal	1	2	2	3	4	8	
Kit, O-ring	1	2	2	3	4	8	
Kit, Impeller fixing	0	1	0	2	0	4	
Kit, Impeller	0	1	0	2	0	4	
Kit, Bearing	0	1	0	2	0	4	
Kit, Moisture switch	0	1	0	2	0	4	
Kit, plug	0	1	0	2	0	4	
Liquid for sub. Motor ¹⁾	0	1	0	2	0	4	

1) See service instruction for amount and type.

Above recommendations are based on:

Agitators running in normal operation should be checked every 3000 operating hours or at least once a year.

If the stirred liquid is very muddy or sandy, check the pump at shorter intervals.

96488862 06.2022

GRUNDFOS Holding A/S
Poul Due Jensens Vej 7
DK-8850 Bjerringbro
Tel: +45 87 50 14 00
www.grundfos.com

GRUNDFOS 